



Town of Paradise

DEVELOPMENT SERVICES

5555 Skyway Paradise, CA 95969

(530) 872-6291 ext. 123 FAX (530) 877-5059

www.townofparadise.com

Mechanical HVAC Installers

2013 California Mechanical Code Requirement

2013 CMC § 1106.4 Refrigerant Port Protection. Air conditioning refrigerant circuit access ports located outdoors shall be protected from unauthorized access with locking-type tamper-resistant caps or in a manner approved by the Authority Having Jurisdiction.

