



# Town of Paradise

DEVELOPMENT SERVICES

5555 Skyway Paradise, CA 95969  
(530) 872-6291 ext. 123 FAX (530) 877-5059

[www.townofparadise.com](http://www.townofparadise.com)

## 2013 California Electrical Code Requirement

**2013 CEC § 250.94 Bonding for Other Systems.** An intersystem bonding termination for connecting intersystem bonding conductors required for other systems shall be provided external to enclosures at the service equipment or metering equipment enclosure and at the disconnecting means for any additional buildings or structures.

