

ATTACHMENT 2

<u>RATING</u>	<u>OBSERVATIONS</u>
EXCELLENT	No noticeable rise in liquid level of septic tank while adding water to tank. Operating Permit will be issued by Town with five to seven year renewal date.
GOOD	Liquid level in septic tank rises approximately one inch above the operating liquid level. Liquid level in septic tank declines to the operating liquid level within fifteen minutes. Operating Permit will be issued by Town with a four year renewal date.
SATISFACTORY	Liquid level in septic tank rises approximately two inches above the operating liquid level. Liquid level in septic tank declines to the stabilized liquid level within fifteen minutes. Operating permit will be issued by Town with a three year renewal date.
MARGINAL	Liquid level in septic tank rises approximately three inches above the operating liquid level but does not overflow the top of the outlet tee fitting. Liquid level in septic tank declines to operating liquid level within thirty minutes. Conditionally approved Operating Permit will be issued by Town with a two year renewal date.
POOR	Liquid level in septic tank rises above the operating liquid level to the top of the tee fitting but does not overflow the tee fitting. Liquid level in septic tank declines but does not reach the operating level in thirty minutes. Conditionally approved Operating Permit will be issued by Town with a one year renewal date.
FAILURE	Liquid level in septic tank rises above the operating level of the septic tank to the soffit of the septic tank. Liquid level declines slightly or not at all within thirty minutes. Onsite wastewater disposal system repair is required.