



Building Inspector Checklist

(Over-the-Counter ELECTRICAL)

Rough Electrical

- Wiring methods compliant. CEC Chapter 3
- Box fill/conductor sizing. CEC 314.16
- Grounding/bonding complete. CEC 250
- Panel access maintained. CEC110.26
- Nail plates installed where required. CRC R602.6
- BESS-ready interconnection CEC 150.0
- Smoke detectors and CM alarms CRC R310-R311.
- Other, see comments.
- Photo: Panel + protection

Underfloor electrical

- Contractor information verified.
- Cable/conduit secured and protected. CEC §334.30, §300.4
- Crawlspace clearances maintained. CEC §110.26
- Other, see comments.
- Photo: Protection at framing

Electrical service equipment

- Contractor information verified.
- Service disconnect provided. CEC 230.70
- Working clearance maintained. CEC 110.26
- Grounding electrode system installed. CEC 250.50
- Other, see comments.
- Photo: Service disconnect

Electrical service tag

- Contractor information verified.
- Panel labeling complete. CEC 408.4
- AFCI/GFCI protection provided. CEC 210.8, 210.12
- No open knockouts. CEC 110.12
- Other, see comments.
- Photo: Panel interior

Underground Electrical

- Contractor information verified.
- Burial depth compliant. CEC Table 300.5
- Warning tape installed. CEC 300.5(D)
- Conduit approved for burial. CEC Chapter 3
- Other, see comments.
- Photo: Trench depth

Final Electrical

- Contractor information verified.
- Service size, circuits, and equipment match approved documents and permit scope. CEC 90.4, 110.3
- Panel directories are complete and accurate. CEC 110.26, 408.4
- Grounding and bonding connections are secure and continuous. CEC Article 250
- Receptacles, switches, and lighting installed and operational. CEC 210.8
- GFCI and AFCI protection provided where required. CEC 210.12
- Smoke and carbon monoxide alarms powered and interconnected. CRC R314, R315
- Other, see comments.
- Photo Required: Panel labeling and grounding electrode

Under Paradise Municipal Code 9.18.160 – Construction or Demolition - Generally, it is unlawful to operate, or cause the operation of, tools or equipment used in construction, drilling, repair, alteration, or demolition during the following times when the noise is clearly audible beyond a residential or commercial property boundary:

- Between 7:00 p.m. and 6:00 a.m. on weekdays
- At any time on Sundays or holidays

Construction activity is not prohibited entirely on Sundays or holidays. Contractors may continue to work during those days, provided the work does not generate noise beyond the property lines. Examples of allowable low-noise activities include interior work such as hanging light fixtures, finish electrical work, interior painting, or similar tasks.

Violations of the Town's construction noise ordinance may result in administrative citations, associated fees, and fines. The Town encourages contractors and property owners to plan work accordingly to avoid penalties and help maintain positive relationships within the community.